

Pursuant to Florida Statute, Section 633.027, (2008), the City of Marathon will start requiring all owners of any commercial, industrial or multiunit residential structure of three units or more constructed of light-frame floor and roof trusses, to install the appropriate symbol adopted by rule of the State Fire Marshal's Office to provide responders to a fire as to the type of roofing and flooring structure. The Fire Marshal's rule establishes the dimensions, color, and location of the symbol to be applied to every commercial, industrial and multiunit residential structure of three units or more constructed of light-frame floor and roof trusses. For more information: call the City of Marathon Fire Marshal's Office at 305- 289-8938



Lightweight Truss Floor



Lightweight Truss Roof



Lightweight Truss Roof & Floor

- ✘ Symbols must be all weather and contrasting with background
- ✘ Maltese Cross shall measure 8 inches horizontally and 8 inches vertically
- ✘ Maltese Cross shall be a bright red reflective color
- ✘ Maltese Cross shall be within 24 inches to the left of the main entry
- ✘ Maltese Cross shall be not less than 4 feet above grade, walking surface, finished floor
- ✘ Maltese Cross shall be not more than 6 feet above grade, walking surface, finished floor
- ✘ Additional signs to be installed as determined by the Authority Having Jurisdiction.
- ✘ The complete rule is available on the State Fire Marshals web site under Rules of the State Fire Marshal